

Level 2 Electric Vehicle Charger Service Load Calculator

INSTRUCTIONS: Review the list of electrical loads in the table below and check all that exist in your home (don't forget to include the proposed Level 2 charger). For each item checked, fill in the corresponding "Watts Used" (refer to the "Typical Usage" column for wattage information). Add up all of the numbers that are written in the "Watts Used" column and write that number in the "TOTAL WATTS USED" box at the bottom of the table. Then go to the next page to determine if your existing electric service will accommodate the new loads.

(Loads shown are rough estimates; actual loads may vary. For a more precise analysis, use the nameplate ratings for appliances and other loads and consult with a trained electrical professional.)

| Check all Applicable Loads (✓) | Description of Load | Typical Usage | Watts Used |
|-------------------------------------|--|--------------------|------------|
| | GENERAL LIGHTING AND RECEPTAC | LE OUTLET CIRCUITS | |
| | Multiply the square footage of house x 3 | 3 watts/sq. ft. | |
| | KITCHEN CIRCUIT | rs | |
| | Kitchen circuits | 3,000 watts | |
| | Electric oven | 2,000 watts | |
| | Electric stove top | 5,000 watts | |
| | Microwave | 1,500 watts | |
| | Garbage disposal under kitchen sink | 1,000 watts | |
| | Automatic dish washer | 3,500 watts | |
| | Garbage compactor | 1,000 watts | |
| | Instantaneous hot water at sink | 1,500 watts | |
| | LAUNDRY CIRCUI | TS | |
| | Laundry circuit | 1,500 watts | |
| | Electric clothes dryer | 4,500 watts | |
| | HEATING AND AIR CONDITION | NING CIRCUITS | |
| | Central heating and air conditioning | 6,000 watts | |
| | Window mounted air conditioning | 1,000 watts | |
| | Whole-house or attic fan | 500 watts | |
| | Central electric furnace | 8,000 watts | |
| | Evaporative cooler | 500 watts | |
| | OTHER ELECTRICAL L | OADS | |
| | Electric water heater (storage type) | 4,000 watts | |
| | Electric tankless water heater | 15,000 watts | |
| | Swimming pool or spa | 3,500 watts | |
| | Other (describe) | | |
| | Other (describe) | | |
| | Other (describe) | | |
| | ELECTRIC VEHICLE CHARG | ER CIRCUIT | |
| | Level 2 electric vehicle charger wattage rational statements and the second sec | ng | |
| | | TOTAL WATTS USED | |

123

INSTRUCTIONS: Using the "TOTAL WATTS USED" number from the previous page, check the appropriate line in column 1 and follow that line across to determine the minimum required size of the electrical service panel shown in column 3. In column 4, write in the size of your existing service panel (main breaker size). If your existing service panel (column 4) is smaller than the minimum required size of the existing service (column 3), then you will need to install a new upgraded electrical service panel to handle the added electrical load from the proposed Level 2 charger.

The table below is based on CEC 220.83(A), 230.42 and Annex D.

| 1 | 2 | 3 | 4 |
|--|--|---|---|
| Check the appropriate line (🗸) | Total Watts Used (from previous page) | Minimum Required Size of Existing 240-Volt Electrical Service Panel (Main Service Breaker Size) | Identify the Size of Your Existing Main Service Breaker (Amps)* |
| | up to 48,000 | 100 amps | |
| | 48,001 to 63,000 | 125 amps | |
| | 63,001 to 78,000 | 150 amps | |
| | 78,001 to 108,000 | 200 amps | |
| | 108,001 to 123,000 | 225 amps | |

*Note that the size of your <u>existing</u> service (column 4) MUST be <u>equal to or larger than</u> the Minimum <u>Required</u> Size (column 3) or a new larger electrical service panel will need to be installed in order to satisfy the electrical load demand of the EV charger.

STATEMENT OF COMPLIANCE

By my signature, I attest that the information provided is true and accurate.

JobAddress:__

(Print job address)

Signature:

(Signature of applicant)

In addition to this document, you will also need to provide a copy of the manufacturer's installation literature and specifications for the Level 2 charger you are installing.

Note: This is a <u>voluntary</u> compliance alternative and you may wish to hire a qualified individual or company to perform a thorough evaluation of your electrical service capacity in lieu of this alternative methodology. Use of this electrical load calculation estimate methodology is at the user's risk and carries no implied guarantee of accuracy. Users of this methodology and these forms are advised to seek professional assistance in determining the electrical capacity of a service panel.

(Date)